# DALC NET

#### **DALCNET S.r.I.**

Registered office: via dei Laghi, 31 - 36077 Altavilla Vicentina (VI) - Italy Headquarters: via A.Meucci, 35 - 36040 Brendola (VI)

Headquarters: via A.Meucci, 35 - 36040 Brendola (VI) - Italy VAT: IT04023100235 - Tel. +39 0444 1836680 www.dalcnet.com - info@dalcnet.com


## Casambi Dimmer D118x18-1224-4CV-CASAMBI

**PRELIMINARY** 

Rev. 04/03/2019 pag. 1/5

Made in Italy





#### **FEATURES**

- DIMMER+CASAMBI
- DC Input: 12-24 Vdc
- Command: APP CASAMBI
- N°4 Output channels
- Control: Dimmer White, Tunable White, RGB e RGBW
- Constant Voltage variant for Common Anode applications
- Voltage outputs for R loads
- Memory function
- $\bullet$  Adjusting the brightness of white light, monochromatic color, Tunable White
- Creating multiple colour scenes and selecting colour games
- · Adjusting the brightness up to completed off
- Soft start and soft stop
- Typical efficiency > 95%
- 100% Functional test

#### CONSTANT VOLTAGE VARIANTS

CODE	Input voltage	Channels	Output	Command	
D118x18-1224-4CV-CBU	12-24V DC	4	4 x 4A (max 6A tot.)	APP CASAMBI	

As default, D80x18-1224-2CV-CBU is delivered with RGB+W configuration

#### PROTECTIONS

[	OVP	Over voltage protection (*)	✓
Ī	RVP	Reverse polarity protection (*)	✓
[	IFP	Input fuse protection (*)	✓

<sup>(\*)</sup> Only control Logic protection

## > TYPE OF PROFILE

PROFILE	Supply Voltage	Output	Channels	Commands		
WHITE	12-24V DC	2 x CV	4	APP CASAMBI		DIMMER
TUNABLE WHITE	12-24V DC	2 x CV	2	APP CASAMBI	TUNABLE WHITE	
RGB	12-24V DC	3 x CV	3	APP CASAMBI		RGB
RGB+W	12-24V DC	4 x CV	3+1	APP CASAMBI	RGB	W



#### **DALCNET S.r.I.**

Registered office: via dei Laghi, 31 - 36077 Altavilla Vicentina (VI) - Italy Headquarters : via A.Meucci, 35 - 36040 Brendola (VI) - Italy VAT: IT04023100235 - Tel. +39 0444 1836680

www.dalcnet.com - info@dalcnet.com

Casambi Dimmer D118x18-1224-4CV-CASAMBI

**PRELIMINARY** 

Made in Italy

Rev. 04/03/2019
pag. 2/5

Device Manual

#### REFERENCE STANDARDS


EN 61347-1	Lamp controlgear - Part 1: General and safety requirements		
	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment		
EN 61547	Equipment for general lighting purposes - EMC immunity requirements		

#### > TECHNICAL SPECIFICATIONS

		Constant voltage			
Supply voltage		min: 10,8 Vdc max: 26,4 Vdc			
Input current		Max 6A			
Channels		4			
Output voltage		= Vin			
Output current		A/ch	A tot		
		4A ¹)	6A 1)		
Absorbed nominal power 1)	@12V	48 W	72 W		
	@24V	96 W	144 W		
Power loss in stand by mode		<500mW			
Type of Load		R			
D-PWM dimming frequency		600 Hz			
D-PWM resolution		833 step			
Operating frequencies		2,400 2,483 GHz			
Maximum output power		4dBm			
D-PWM range		0 – 100%			
Storage Temperature		min: -40 max: +60 °C			
Ambient Temperature <sup>1)</sup>		min: -10 max: +40 °C			
Wiring		0,2 0,75mm² – 24 18 AWG Solid Sizes 0,2 0,75mm² – 24 18 AWG Stranded Sizes			
Wire preparation length		7 ÷ 10mm			
Mechanical dimensions		118 x 18 x 6 mm			
Fixing		Biadhesive			
Weight		13 g			

<sup>&</sup>lt;sup>1)</sup> Maximum value, dependent on the dissipation conditions. This value is measured at 40°C, it is maximum ambient temperature.

### MECHANICAL DIMENSION



# **DALC** NET

#### DALCNET S.r.I.

Registered office:

via dei Laghi, 31 - 36077 Altavilla Vicentina (VI) - Italy Headquarters: via A.Meucci, 35 - 36040 Brendola (VI) - Italy VAT: IT04023100235 - Tel. +39 0444 1836680 www.dalcnet.com - info@dalcnet.com

# Casambi Dimmer

D118x18-1224-4CV-CASAMBI

Made in Italy Rev. 04/03/2019 **PRELIMINARY** pag. 3/5


#### **Device Manual**


#### INSTALLATION


To set the product, follow the instruction on the picture below:


- 1) Fix the Casambi Dimmer to the aluminium profile by the provided thermal biadhesive
- 2) connect the LED in the output of the dimmer
- 3) connect the power supply in the input of the dimmer

DIMMER CASAMBI as any other Casambi product, should not be placed in a metal enclosure or next to large metal structures. Metal will effectively block all radio signals which are crucial to the operation of the product.









# **DALC** NET

#### DALCNET S.r.I.

Registered office:

via dei Laghi, 31 - 36077 Altavilla Vicentina (VI) - Italy Headquarters: via A.Meucci, 35 - 36040 Brendola (VI) - Italy VAT: IT04023100235 - Tel. +39 0444 1836680 www.dalcnet.com - info@dalcnet.com

## Casambi Dimmer D118x18-1224-4CV-CASAMBI


**PRELIMINARY** 

Rev. 04/03/2019 pag. 4/5

Device Manual

## Wiring diagram: RGB





Channel 1: Dimmer




Made in Italy

Channel 2: Colour




Channel 3: Colour saturation





Wiring diagram: RGB+W





Channel 1: Dimmer




Channel 2: White / Colour



Channel 3: Temperature color





Channel 4: Colour saturation





#### DALCNET S.r.I.

Registered office: via dei Laghi, 31 - 36077 Altavilla Vicentina (VI) - Italy Headquarters : via A.Meucci, 35 - 36040 Brendola (VI) - Italy VAT: IT04023100235 - Tel. +39 0444 1836680 www.dalcnet.com - info@dalcnet.com

# Casambi Dimmer D118x18-1224-4CV-CASAMBI PRELIMINARY

Made in Italy

Rev. 04/03/2019 pag. 5/5

**Device Manual** 

#### TECHNICAL NOTE

#### Installation:

- Installation and maintenance must be performed only by qualified personnel in compliance with current regulations.
- The product must be dissipated correctly.
- Keep separated the circuits at 230V (LV) and the circuits not SELV from circuits to low voltage (SELV) and from any connection with this product. It is absolutely forbidden to connect, for any reason whatsoever, directly or indirectly, the 230V mains voltage to the bus or to other parts of the circuit.

#### Power Supply:

- For the power supply use only a SELV power supplies with limited current, short circuit protection and the power must be dimensioned correctly. In case of using power supply with ground terminals, all points of the protective earth (PE = Protection Earth) must be connected to a valid and certified protection earth.
- The connection cables between the power source "low voltage" and the product must be dimensioned correctly and they should be isolated from every wiring or parts at voltage not SELV. It is suggested to use double insulated shielded.
- Dimension the power supply for the load connected to the device. If the power supply is oversized compared with the maximum absorbed current, insert a protection against over-current between the power supply and the device.

#### Outputs:

• T	he length of the connection cal	bles between the product	and the LED module r	must be less than 10m	n; the cables must be c	iimensioned correctly and
the	y should be isolated from every	y wiring or parts at voltage	e not SELV. It is sugge	sted to use double ins	sulated shielded and tv	visted cables.